

VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

| | |
|--|---|
| School District: | 47 - Powell River |
| School Name: | Henderson |
| REQUIREMENT: Regular inspection and maintenance of HVAC systems | Yes/No: Yes |
| | Date of last inspection: 2022-09-07 |
| | Date of next inspection: 2022-11-08 |
| | Date and type of most recent maintenance: 202-09-07. Confirm Operation of all HVAC Equipment. Changed all filters. |
| RECOMMENDATION: Increase supply of outside air | Yes/No: Yes |
| | Detail: Outside Air Dampers Set to 55% from previous service. Confirmed |
| RECOMMENDATION: Upgrade filtration, including installing MERV-13 filters, where possible | Yes/No: Yes |
| | Detail (Including filter grade): All unit have Merv 13 Filters installed. |
| RECOMMENDATION: Use other air cleaning or treatment technologies | Yes/No: Yes |
| | Detail: Occupancy/Run times were expanded during previous service from 6am-10pm. |
| RECOMMENDATION: Manage energy use and air distribution through building automation control systems | Yes/No: No |
| | Detail: |
| Other Relevant Information: | |
| District Contact for any Questions: | Name: Casey Jantz |
| | Phone Number: 604 223-3954 |
| | Email: Casey.Jantz@sd47.bc.ca |