

VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

School District:	47 - Powell River
School Name:	Oceanview
REQUIREMENT: Regular inspection and maintenance of HVAC systems	Yes/No: Yes
	Date of last inspection: 2022-09-05
	Date of next inspection: 2022-11-07
	Date and type of most recent maintenance: 2022-09-05. Confirm Operation of all HVAC Equipment. Changed all Filters.
RECOMMENDATION: Increase supply of outside air	Yes/No: Yes
	Detail: Outside Air Dampers set to 55% during last service. Confirmed.
RECOMMENDATION: Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: Yes
	Detail (Including filter grade): All units have Merv 13 Filters installed.
RECOMMENDATION: Use other air cleaning or treatment technologies	Yes/No: Yes
	Detail: Occupancy/Run Times were expanded during last service 6am-10pm.
RECOMMENDATION: Manage energy use and air distribution through building automation control systems	Yes/No: No
	Detail:
Other Relevant Information:	
District Contact for any Questions:	Name: Casey Jantz
	Phone Number: 604 223-3954
	Email: Casey.Jantz@sd47.bc.ca